



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From,
 The Commissioner,
 Greater Visakhapatnam
 Municipal Corporation
 Visakhapatnam.

To,
 The District Educational Officer,
 Visakhapatnam District,
 Visakhapatnam.

Rc.No:112/RFO/FPW/GVMC/2026, Dated:24-03-2026

SUB: Greater Visakhapatnam Municipal Corporation – Fire Prevention Wing – Existing Building of M/s.Jubilee E.M. School, D.No.34-2-97/1, Geddaveedhi, Gnanapuram, Visakhapatnam – Renewal Of Fire No Objection Certificate Issued - Reg.

- REF:** 1. Letter Rc.No: 5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
 2. Delegation orders of Commissioner madam vide Rc.No.6721/2012/TP. Sec/G1 Dt: 13/09/2019.
 3. Circular Memorandum Rc.No.3350/Audit/NOC/2012, Dt.01-09-2025 of Director General, A.P Disaster Response & Fire Services Department, Vijayawada.
 4. This office Fire No Objection Certificate for Occupancy issued vide Rc.No.010737/15/GVMC/FPW, Dt.31-08-2015.
 5. This office Renewal of Fire No Objection Certificate issued vide Rc.No.049/RFO/FPW/GVMC/2022, Dt.01-02-2022
 6. Application Dt.18-03-2026 of M/s.Jubilee English Medium School, D.No.34-2-97/1, Geddaveedhi, Gnanapuram, Visakhapatnam for Renewal of Fire No Objection Certificate.
 7. Report of the Inspection Committee, FPW, Dt.23-03-2026.

It is to inform that, vide reference 4th cited, Fire No Objection Certificate for Occupancy was issued to M/s.Jubilee English Medium School, D.No.34-2-97/1, Geddaveedhi, Gnanapuram, Visakhapatnam and vide reference 5th cited, the management obtained Renewal of Fire No Objection Certificate

2. Vide reference 5th cited, an application is received by this office for issuance of Renewal of Fire No Objection Certificate to the same building.

3. Therefore, Inspection Committee of District Fire Officer and Station Fire Officer, Fire Prevention wing, GVMC inspected the premises of M/s.Jubilee English Medium School, D.No.34-2-97/1, Geddaveedhi, Gnanapuram, Visakhapatnam on 23-03-2026 and submitted the following report.

4. Particulars of the building:

a) Address of the Premises	M/s.Jubilee English Medium School, D.No.34-2-97/1, Geddaveedhi, Gnanapuram, Visakhapatnam
----------------------------	---



Chetty

10. Means of Escape:

- The management provided One internal staircase with a width of 1.50 Mtrs. and one external staircase with a width of 1.50 Mtrs. which are sufficient for occupant load.

11. The Minimum Fire Safety Installations required & provided by the Builder as per the Table 23 of Part-4 of N.B.C of India 2005

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS-2190	15 Nos.	15 Nos.	Nil
2.	Hose Reel	01 No. in each floor	01 No. in each floor	Nil
3.	Down Comer	Not Required	01 No.	Nil
4.	Terrace Tank	10,000 Ltrs	10,000 Ltrs	Nil
5.	Booster Pump of	450 LPM	450 LPM	Nil
6.	Two way fire Brigade inlet	Required	Provided	Nil

12. The management has remitted an amount of Rs.48,090/- vide challan No.2025-CH-10908, Dt.18-03-2026 paid at sowkaryam, GVMC, Visakhapatnam towards Fire precautionary fee for 03 years.

13. The Fire safety systems were tested by the Station Fire Officer, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.

14. Therefore, Renewal of Fire No Objection Certificate is hereby issued to the Educational Building of M/s.Jubilee English Medium School, D.No.34-2-97/1, Geddaveedhi, Gnanapuram, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the firefighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

15. The **Renewal of Fire No Objection Certificate** issued to M/s.Jubilee



10. Means of Escape:

- The management provided One internal staircase with a width of 1.50 Mtrs. and one external staircase with a width of 1.50 Mtrs. which are sufficient for occupant load.

11. The Minimum Fire Safety Installations required & provided by the Builder as per the Table 23 of Part-4 of N.B.C of India 2005

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS-2190	15 Nos.	15 Nos.	Nil
2.	Hose Reel	01 No. in each floor	01 No. in each floor	Nil
3.	Down Comer	Not Required	01 No.	Nil
4.	Terrace Tank	10,000 Ltrs	10,000 Ltrs	Nil
5.	Booster Pump of	450 LPM	450 LPM	Nil
6.	Two way fire Brigade inlet	Required	Provided	Nil

12. The management has remitted an amount of Rs.48,090/- vide challan No.2025-CH-10908, Dt.18-03-2026 paid at sowkaryam, GVMC, Visakhapatnam towards Fire precautionary fee for 03 years.

13. The Fire safety systems were tested by the Station Fire Officer, Fire Prevention Wing, GVMC during the inspection and performance found satisfactory and recommended for issuance of Renewal of Fire No Objection Certificate.

14. Therefore, Renewal of Fire No Objection Certificate is hereby issued to the Educational Building of M/s.Jubilee English Medium School, D.No.34-2-97/1, Geddaveedhi, Gnanapuram, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the firefighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.



15. The Renewal of Fire No Objection Certificate issued to M/s.Jubilee

Chdye

English Medium School, D.No.34-2-97/1, Geddaveedhi, Gnanapuram, Visakhapatnam is valid from 15-03-2026 to 14-03-2029 and the Management shall submit the application for Renewal of Fire NOC two (2) months before the date of expiry.

16. The issuing of Fire NOC will be without any prejudice to the action taken by GVMC against Unauthorized Construction, if any made by GVMC.

CH KRUPAVARAM, RFO(CHK)-RFO(TP)-GVMC, O/o REGIONAL FIRE OFFICER-TOWN PLANNING-GVMC



Chellu
Regional Fire Officer
Fire Prevention Wing, GVMC
Visakhapatnam

Copy to the Management, M/s.Jubilee English Medium School, D.No.34-2-97/1, Geddaveedhi, Gnanapuram, Visakhapatnam.

Sr. Anthony
HEAD MISTRESS
JUBILEE ENG. MED. HIGH SCHOOL
GNANAPURAM
VISAKHAPATNAM-530 004